



South Pars Gas Field Development Phase 12 Onshore Facilities - EPC3

Request for Material Approval (RMA)

Contract No :	CCA /88 / 3175	Document No : Field Procurement
RMA No :	RMA3-CV-00168	Date : 19-Sep-12
Material Description :	Epoxi Grout G3 - Kariz Grout , EG310	
Vendor Name :	Kariz Hydro Sazeh	
Vendor Reference : (To be filled by)	Approved Vendor ☐ None Approved Vendor ☐ Others: ☒ <i>N/A at A/V/L</i>	<i>H. Fatemi</i>
Respective Work Package (Specify):	Plant (EPC 3)	
Drawing No(s) :	ALL Vibration Foundation Const. Items	
Acceptance Criteria :	According to Drawing	
Attachments:	Sample ☐ Catalogue ☒ Certificates ☐ Others: ☐	
Contractor:	<i>KH-Valipoor</i>	
Company Comments:	<i>Demonstration is required. The approval of material is subjected to confirmation of strength and quality at the site.</i>	
APPROVAL and SIGNATURES		
CONTRACTOR :		
Engineering Department	Site Manager	
Name: <i>KH- VALIPOUR</i>	Name: <i>S-VAHEDIAN</i>	
Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>	
Engineering Department		
Name: <i>a. tabrizi</i>	Name: <i>For A. Nafati</i>	
Signature: <i>22-Sep-2012</i>	Signature: <i>22-Sep-12</i>	
RMA Approval Status:	Approved ☐ Approved with Comment ☒ Rejected ☐	

Notice: All of the colored field will be filled by Company.